



## GENERAL INFORMATION - UNDERGROUND PROJECTS - RULE 13

Reference to "Rule 13" is made in our agreement for installation of underground electric lines.

"Rule 13" is on file with, and approved by, the Indiana Utility Regulatory Commission, and copies are available from IPL upon request or on page 10 at <http://www.aes.com/pub-sites/IPL/content/staging/0205017431b9010a483052b3006d66/rules.pdf>. This rule includes information required from, and work to be done by, the Developer. This general information does not replace or substitute for "Rule 13", as this is intended merely for a quick review of the rule. This information is also found in the Electric Service and Meter Manual (Goldbook) in Section 220 found at <http://apps.iplpower.com/goldbook/>.

1. The Developer must provide the following drawings:
  - A. Site plan or plat of project showing property lines and building locations;
  - B. Construction plans in sufficient detail to confirm service and load information;
  - C. Topographic plans showing final grades; and
  - D. Sanitary sewer, storm sewers and all other drainage facilities.
2. The Developer shall pay all costs incurred by the Company (IPL) which are the result of changes in information from that previously supplied to the Company.
3. All necessary easements and rights-of-way shall be furnished by the Owner or Developer at no cost to the Company.
4. The Developer shall furnish and install conduit from the meter or junction box to a point where all paved areas are cleared by at least two feet. The Developer shall also furnish and install all conduit required to clear by at least two feet all sidewalks, parking lots or similar obstructions.
5. For all cable routes to be trenched by the Company, the Developer shall:
  - A. Stake all property corners, structures and any underground facilities such as pipelines or sewers.
  - B. Grade all trench routes to within four inches of final grade.
  - C. Clear all surface and subsurface obstructions which prevent the use of standard trenching equipment to a depth of forty two inches below final grade. Any damage to persons or property resulting from the failure of the Developer to maintain clearance or provide a depth of forty two inches below the surface of the ground shall be assumed and paid for by the Developer.
  - D. Be responsible for maintaining the grade and clearance of such trench routes during and subsequent to the Company's work in installing the electric lines underground.

If the Company employs nonstandard methods of equipment not contemplated, the Developer shall pay the difference in cost between the standard method, as estimated by the Company, and such nonstandard method.

Please refer questions regarding the above to the Distribution Engineering Department of IPL, Phone (317) 261-8576 or (317) 261-8196.

CUSTOMER SERVICE - (317) 261-8222  
U.R.D. SERVICE COORDINATOR - (317) 261-8284